



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16215-37-194
State Number
15427

EQUIPMENT INSPECTED

State Number: 15427	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 10/11/1994	Rope Size:
Volts: 208	Complied: 10/14/1994	Entrances: 1
OWNER ALAMANCE - BURLINGTON SCHOOL SYSTEM 1712 VAUGHN RD BURLINGTON, NC, 27217		OCCUPANT TURRENTINE MIDDLE SCHOOL 1710 EDGEWOOD AVE BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date 08/02/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 37 - Hopper	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	--------------------------	--------------------

VIOLATIONS

2.27.1.1.2	Put the in car emergency telephone in proper working order.
8.7	TAKE STEPS TO ELIMINATE CAR DOORS SLAMMING SHUT
8.6	PROVIDE WORKING CAB LIGHTS

Items must be corrected by: 09/01/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: FREDRICK SELLARS 336-570-6150

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE - BURLINGTON SCHOOL SYSTEM
1712 VAUGHN RD
BURLINGTON, NC, 27217