



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**16215-37-2132**  
State Number  
**18087**

EQUIPMENT INSPECTED

State Number: <b>18087</b>	Type of Unit: Passenger	Floor to Floor: 1F to 1R
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 03/10/1999	Rope Size:
Volts: 480	Complied: 03/10/1999	Entrances: 2
OWNER	OCCUPANT	
NATIONAL SPINNING CO INC	NATIONAL SPINNING CO INC	
142 GLEN HAVEN RD	142 GLEN HAVEN RD	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 08/02/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 37 - Hopper	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	--------------------------	--------------------

1

VIOLATIONS

8.6 UPDATE THE FIRE EXTINGUISHER ( 2 YEARS OUT OF DATE )

Items must be corrected by: 09/01/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: SUSAN 336-539-0912

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

NATIONAL SPINNING CO INC  
142 GLEN HAVEN RD  
BURLINGTON, NC, 27215