



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**16215-37-288**  
State Number  
**24757**

EQUIPMENT INSPECTED

State Number: <b>24757</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: OTIS	Speed: 125
Landings: 2	Installed: 07/23/2007	Rope Size: 0
Volts: 208	Complied: 07/23/2007	Entrances: 1
OWNER	OCCUPANT	
FIDELITY BANK	FIDELITY BANK	
100 S MAIN STREET	2517 S. CHURCH STREET	
FUQUAY VARINA, NC, 27526	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 08/02/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 37 - Hopper	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	--------------------------	--------------------

1

VIOLATIONS

2.27.1.1.2	Put the in car emergency telephone in proper working order.
8.6	PROVIDE ACCESS TO EQUIPMENT ROOM ( CANNOT ACCESS DOOR KNOB BROKE)

Items must be corrected by: 09/01/2016

Elevator Name: FIDELITY BANK # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JOSH STONE 336-227-1157

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

FIDELITY BANK  
100 S MAIN STREET  
FUQUAY VARINA, NC, 27526