



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16215-48-1840
State Number
22375

EQUIPMENT INSPECTED

State Number: 22375	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 06/24/2004	Rope Size: .
Volts: 208	Complied: 06/24/2004	Entrances: 1
OWNER	OCCUPANT	
TONIA GOUDARZI	SOUTHPORT COMMONS BLDG 1	
TG MANAGEMENT	1456 N HOWE ST	
WILMINGTON, NC, 28403	SOUTHPORT, NC, 28461	

INSPECTION INFORMATION

Inspection Date 08/02/2016	Type Inspection Routine	Certificate Status Not Issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	----------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.7.1 Clean the elevator pit.
2.27.1.1.2 Put the in car emergency telephone in proper working order.
8.1.1[c] Keys shall be kept on the premises in a location readily accessible to the personnel in the assigned group, but not where they are accessible to the general public.
N/A PARTIAL INSP.

Items must be corrected by: 10/02/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

TONIA GOUDARZI
TG MANAGEMENT
WILMINGTON, NC, 28403