



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16217-36-4842
State Number
14792

EQUIPMENT INSPECTED

State Number: 14792	Type of Unit: Freight	Floor to Floor: 1 to 2
Capacity: 12600	Manuf: ASK	Speed: 45
Landings: 2	Installed: 08/28/1992	Rope Size:
Volts: 480	Complied: 08/28/1992	Entrances: 1
OWNER	OCCUPANT	
CAROLINA HOISERY MILLS, INC.	AMERICAN MULTI MEDIA	
PO BOX 850	2609 TUCKER ST	
BURLINGTON, NC, 27216	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 08/04/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

8.6.5.7	Provide an oil usage log.
8.11.2.3.1	Provide the annual no load test.
8.6.1.2.1	Provide a written maintenance program.
2.7.3.4.1(b)	Provide a self closing, self locking machine room door.

Items must be corrected by: 09/03/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: KIETH GREESON 336-260-2676

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CAROLINA HOISERY MILLS, INC.
PO BOX 850
BURLINGTON, NC, 27216