



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16217-48-4430
State Number
H1749

EQUIPMENT INSPECTED

State Number: H1749	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: GARAVENTA	Speed: 17
Landings: 2	Installed: 09/07/2006	Rope Size: 0
Volts: 120	Complied: 09/07/2006	Entrances: 1
OWNER	OCCUPANT	
OCEAN ISLE BEACH	RESORT AT OIB	
103 W 1ST STREET	103 W 1ST STREET	
OCEAN ISLE, NC, 28469	OCEAN ISLE, NC, 28469	

INSPECTION INFORMATION

Inspection Date 08/04/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.13.1[a] Properly maintain hoist way door interlocks or mechanical locks and electric contacts [1ST FL]

Items must be corrected by: 10/04/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: DONNA

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

OCEAN ISLE BEACH
103 W 1ST STREET
OCEAN ISLE, NC, 28469