



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16224-48-2924
State Number
22761

EQUIPMENT INSPECTED

State Number: 22761	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 3500	Manuf: OTIS	Speed: 125
Landings: 4	Installed: 06/02/2005	Rope Size:
Volts: 208	Complied: 06/02/2005	Entrances: 1
OWNER	OCCUPANT	
HARBORSIDE CONDO'S COA	HARBORSIDE CONDOS @ S.P.	
1861 RAEFORD RD.	600 W WEST STREET	
SOUTHPORT, NC, 28461	SOUTHPORT, NC, 28461	

INSPECTION INFORMATION

Inspection Date 08/11/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.8.9 Signs. Caution signs shall be provided. Damaged or missing signs shall be replaced. [LEVELS P,1,2] [SAME AS LAST YR]
8.6.4.7.1 Clean the elevator pit. [SAME AS LAST YR.]

Items must be corrected by: 10/11/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

HARBORSIDE CONDO'S COA
1861 RAEFORD RD.
SOUTHPORT, NC, 28461