



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**16229-8-2950**  
State Number  
**12820**

EQUIPMENT INSPECTED

State Number: <b>12820</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: OTIS	Speed: 125
Landings: 3	Installed: 12/20/1988	Rope Size:
Volts: 208	Complied: 12/20/1988	Entrances: 1
OWNER	OCCUPANT	
ALAMANCE COMMUNITY COLLEGE	ALAMANCE COMMUNITY COLLEGE	
1247 JIMMIE-KERR RD	1247 JIMMIE-KERR ROAD	
GRAHAM, NC, 27253	GRAHAM, NC, 27253	

INSPECTION INFORMATION

Inspection Date 08/16/2016	Type Inspection Compliance	Certificate Status Prev Issued	Inspector 8 - Burris	County ALAMANCE
-------------------------------	-------------------------------	-----------------------------------	-------------------------	--------------------

1

VIOLATIONS

- 8.6.11.3 KEEP ALL ELEVATOR EMERGENCY KEYS ACCESSIBLE TO EMERGENCY PERSONNEL ( HOISTWAY DOOR KEY, FIRE SR KEY & ELEVATOR MACHINE ROOM KEY) FOR ALL ELEVATORS.
- 8.6.4.13.1 MAKE BOTTOM FLOOR HOISTWAY DOOR SELF CLOSE & LOCKING
- 8.6.4.13 REPLACE BOTTOM HOISTWAY DOOR LOCK ROLLER
- 8.6.4.19.4 REPLACE ROLLER ON UP LIMIT SWITCH
- 8.6.11.1 RESTORE FUNCTION OF PHASE II FIRE SERVICE

Items must be corrected by: 10/16/2016

Elevator Name: A BLDG @ MAINT SHOP

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: RONNIE KANUPPS (MAINT)

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE COMMUNITY COLLEGE  
1247 JIMMIE-KERR RD  
GRAHAM, NC, 27253