



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16231-8-2396
State Number
16005

EQUIPMENT INSPECTED

State Number: 16005	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: US	Speed: 115
Landings: 3	Installed: 05/22/1996	Rope Size:
Volts: 208	Complied: 05/24/1996	Entrances: 1
OWNER	OCCUPANT	
ALAMANCE COMMUNITY COLLEGE	ALAMANCE COMMUNITY COLLEGE	
1247 JIMMY KERR RD	1247 JIMMY KERR RD	
GRAHAM, NC, 27253	GRAHAM, NC, 27253	

INSPECTION INFORMATION

Inspection Date 08/18/2016	Type Inspection Compliance	Certificate Status Prev Issued	Inspector 8 - Burris	County ALAMANCE
-------------------------------	-------------------------------	-----------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6.4.15	RESTORE EMERGENCY LIGHTING
8.10.2.2.2	MISSING ELEVATOR NUMBER INSIDE ELEVATOR CAR
8.6.4.16	CHECK ELEVATOR LEAK DN

Items must be corrected by: 10/18/2016

Elevator Name: B BLDG CAR 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: RONNIE KANUPPS

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ALAMANCE COMMUNITY COLLEGE
1247 JIMMY KERR RD
GRAHAM, NC, 27253