N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16231-8-4010
State Number
24960

EQUIPMENT INSPECTED

State Number: **24960**
Capacity: 3000
Landings: 3
Volts: 480

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 08/21/2007
Complied:

Floor to Floor: 1 to 3
Speed: 125
Rope Size:
Entrances: 1

OWNER
ALAMANCE COMMUNITY COLLEGE
1247 JIMMIE KERR ROAD
GRAHAM, NC, 27253

OCCUPANT
ALAMANCE CC ALLIED HEALTH/PHY SCIENCE
1247 JIMMY KERR RD
GRAHAM, NC, 27253

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
08/18/2016	Compliance	Prev Issued	8 - Burris	ALAMANCE

1

VIOLATIONS

2.7.1.1.3 IMPROPER ID ADDRESS FROM MONITORING COMPANY FOR EMERGENCY PHONE
8.6.4.10 RESTORE OPERATION OF CAR DOOR RESTRICTOR
2.7.3.4.1 MAKE MACHINE ROOM DOOR SELF CLOSE & LOCKING

Items must be corrected by: 10/18/2016

Elevator Name: H BLDG CAR 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: RONNIE KANUPPS

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ALAMANCE COMMUNITY COLLEGE
1247 JIMMIE KERR ROAD
GRAHAM, NC, 27253