



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16235-70-1088
State Number
H832

EQUIPMENT INSPECTED

State Number: H832	Type of Unit: Hand Lift	Floor to Floor: LL to UL
Capacity: 750	Manuf: RENAME	Speed: 15
Landings: 2	Installed: 01/09/1998	Rope Size: 1/4
Volts: 110	Complied: 01/09/1998	Entrances: 1
OWNER	OCCUPANT	
FIRST PRESBYTERIAN CHURCH	FIRST PRESBYTERIAN CHURCH	
P.O.BOX 351	208 S. GREEN STREET	
WADESBORO, NC, 28170	WADESBORO, NC, 28170	

INSPECTION INFORMATION

Inspection Date 08/22/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 70 - Darnley	County ANSON
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

4

VIOLATIONS

8.11.2.3.2 Provide the five year full load test. (provide all required testing and leave test data on unit)

Items must be corrected by: 10/22/2016

Elevator Name: HANDICAP LIFT

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Rose Marie Simpson

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

FIRST PRESBYTERIAN CHURCH
P.O.BOX 351
WADESBORO, NC, 28170