



INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**16235-70-176**  
State Number  
**8131**

EQUIPMENT INSPECTED

State Number: <b>8131</b>	Type of Unit: Freight	Floor to Floor: 1 to 4
Capacity: 4000	Manuf: SOUTHERN	Speed: 100
Landings: 4	Installed: 04/22/1975	Rope Size:
Volts: 0	Complied: 04/28/1975	Entrances: 1
OWNER	OCCUPANT	
UNIVERSAL FIBER SYSTEMS LLC	PREMIERE FIBERS INC	
PO BOX 436	HWY 52 N	
ANSONVILLE, NC, 28007	ANSONVILLE, NC, 28007	

INSPECTION INFORMATION

Inspection Date 08/22/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 70 - Darnley	County ANSON
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

4

VIOLATIONS

8.6.4.9	Clean the car top of all debris.
2.14.4.7	Replace or repair the damaged car gate. (Properly install gate cables
2.11.11.5	Replace or repair the damaged hoistway doors.(replace missing door straps)
8.6.4.8.1	Clean the elevator machine room.Oil Pann under pump unit is leaking oil onto machine room floor)
8.11.3.2.1	Provide the annual relief valve and system pressure test.

Items must be corrected by: 10/22/2016

Elevator Name: SMALL FREIGHT ELEV

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Suresh Sundaramoorthy

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

UNIVERSAL FIBER SYSTEMS LLC  
PO BOX 436  
ANSONVILLE, NC, 28007