



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16235-70-3793
State Number
N4.6

EQUIPMENT INSPECTED

State Number: N4.6	Type of Unit: Freight	Floor to Floor: B to 3
Capacity: 0	Manuf: WESTBROOK	Speed: 50
Landings: 4	Installed: 01/01/1978	Rope Size: 5/8
Volts: 220	Complied: 08/29/1978	Entrances: 1
OWNER	OCCUPANT	
H W LITTLE & CO	H W LITTLE & CO	
109 S. GREEN ST.	109 S. GREEN ST.	
WADESBORO, NC, 28170	WADESBORO, NC, 28170	

INSPECTION INFORMATION

Inspection Date 08/22/2016	Type Inspection Removed	Certificate Status Not Issued	Inspector 70 - Darnley	County ANSON
-------------------------------	----------------------------	----------------------------------	---------------------------	-----------------

4

VIOLATIONS

NCAC Unit out of service . Do not use elevator until unit is repaired and reinspected)

Items must be corrected by: 08/22/2017

Elevator Name: FREIGHT ELEVATOR

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: .

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

H W LITTLE & CO
109 S. GREEN ST.
WADESBORO, NC, 28170