



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16235-70-5045
State Number
15555

EQUIPMENT INSPECTED

State Number: 15555	Type of Unit: Freight	Floor to Floor: 1 to 4
Capacity: 10000	Manuf: THYSSEN KRUPP	Speed: 75
Landings: 4	Installed: 12/02/1994	Rope Size:
Volts: 0	Complied: 12/21/1994	Entrances: 1
OWNER	OCCUPANT	
UNIVERSAL FIBER SYSTEMS LLC	PREMIERE FIBERS INC	
PO BOX 436	HWY 52 N	
ANSONVILLE, NC, 28007	ANSONVILLE, NC, 28007	

INSPECTION INFORMATION

Inspection Date 08/22/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 70 - Darnley	County ANSON
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

4

VIOLATIONS

8.11.3.2.1 Provide the annual relief valve and system pressure test.

Items must be corrected by: 10/22/2016

Elevator Name: BIG FREIGHT ELEV

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Suresh Sundaramoorthy

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

UNIVERSAL FIBER SYSTEMS LLC
PO BOX 436
ANSONVILLE, NC, 28007