



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**16237-70-5018**  
State Number  
**21243**

#### EQUIPMENT INSPECTED

|                                    |                         |                                    |
|------------------------------------|-------------------------|------------------------------------|
| State Number: <b>21243</b>         | Type of Unit: Passenger | Floor to Floor: 2 to .1            |
| Capacity: 4500                     | Manuf: THYSSEN KRUPP    | Speed: 125                         |
| Landings: 1                        | Installed: 09/04/2003   | Rope Size: 0                       |
| Volts: 480                         | Complied: 09/04/2003    | Entrances: 1                       |
| OWNER                              |                         | OCCUPANT                           |
| LANESBORO CORRECTIONAL INSTITUTION |                         | LANESBORO CORRECTIONAL INSTITUTION |
| P.O.BOX 280                        |                         | 552 PRISON CAMP RD                 |
| POLKTON, NC, 28135                 |                         | POLKTON, NC, 28135                 |

#### INSPECTION INFORMATION

|                               |                            |                                 |                           |                 |
|-------------------------------|----------------------------|---------------------------------|---------------------------|-----------------|
| Inspection Date<br>08/24/2016 | Type Inspection<br>Routine | Certificate Status<br>Re-issued | Inspector<br>70 - Darnley | County<br>ANSON |
|-------------------------------|----------------------------|---------------------------------|---------------------------|-----------------|

4

#### VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 10/24/2016

Elevator Name: UNION BLDG

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Officer Houpt

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LANESBORO CORRECTIONAL INSTITUTION  
P.O.BOX 280  
POLKTON, NC, 28135