



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**16238-70-5283**  
State Number  
**14303**

#### EQUIPMENT INSPECTED

State Number: <b>14303</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 3	Installed: 02/21/1991	Rope Size:
Volts: 230	Complied: 02/21/1991	Entrances: 1
OWNER	OCCUPANT	
FIRST UNITED METHODIST CHURCH	FIRST UNITED METHODIST CHURCH	
118 E MORGAN ST	118 E MORGAN ST	
WADESBORO, NC, 28170	WADESBORO, NC, 28170	

#### INSPECTION INFORMATION

Inspection Date 08/25/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 70 - Darnley	County ANSON
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

4

#### VIOLATIONS

- 8.6.4.8.2 Remove all materials from machine room (machinery space) not pertaining to the maintenance or operation of the elevator(s).
- 8.6.1.6.5 Provide a class ABC fire extinguisher in machinery space.
- 2.14.7.1.3 Put the in car emergency light in working order.
- 8.11.2.3.1 Provide the annual no load test.
- 8.6 Properly label Elevator Main disconnect and elevator lights disconnect

Items must be corrected by: 10/25/2016

Elevator Name: PASSENGER ELEV

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Lonnie Baucom

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

FIRST UNITED METHODIST CHURCH  
118 E MORGAN ST  
WADESBORO, NC, 28170