



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16244-48-0280
State Number
14615

EQUIPMENT INSPECTED

State Number: 14615	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: OTIS	Speed: 125
Landings: 2	Installed: 09/17/1992	Rope Size:
Volts: 480	Complied: 10/01/1992	Entrances: 1
OWNER	OCCUPANT	
SMITHFIELD PACKING	CAROLINA FOOD PROCESSOR	
1911 S. CHURCH ST.	NC HWY. 87S	
SMITHFIELD, VA, 23430	TARHEEL, NC, 28392	

INSPECTION INFORMATION

Inspection Date 08/31/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BLADEN
-------------------------------	----------------------------	---------------------------------	--------------------------	------------------

9

VIOLATIONS

2.14.1.5.1	Secure the car top emergency exit.
2.14.7.1.3	Put the in car emergency light in working order.
8.6.4.7.1	Clean the elevator pit.
2.27.1.1.2	Put the in car emergency telephone in proper working order AND REPAIR EMERGENCY TELEPHONE DOOR
8.11.2.2.2	Perform the annual no load safety test
N/A	PROVIDE MISSING CEILING TILE IN CAR

Items must be corrected by: 10/31/2016

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: DENNIS PARKS

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SMITHFIELD PACKING
1911 S. CHURCH ST.
SMITHFIELD, VA, 23430