



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**16244-48-4969**  
State Number  
**15582**

#### EQUIPMENT INSPECTED

State Number: <b>15582</b>	Type of Unit: Freight	Floor to Floor: 1 to 2
Capacity: 12000	Manuf: OTIS	Speed: 75
Landings: 2	Installed: 11/23/1994	Rope Size:
Volts: 480	Complied: 12/05/1994	Entrances: 1
OWNER	OCCUPANT	
SMITHFIELD PACKING	CAROLINA FOOD PROCESSORS	
1911 S. CHURCH ST.	NC HWY. 87S	
SMITHFIELD, VA, 23430	TARHEEL, NC, 28392	

#### INSPECTION INFORMATION

Inspection Date 08/31/2016	Type Inspection Removed	Certificate Status Not Issued	Inspector 48 - Martin	County BLADEN
-------------------------------	----------------------------	----------------------------------	--------------------------	------------------

9

#### VIOLATIONS

8.6.4.13.1	All landing and car-door or gate mechanical and electrical components shall be maintained to ensure safe and proper operation. [CAR GATE AND 2ND FLOOR SHAFT DOOR]
2.11.12.8	Provide the missing pull straps. [CAR GATE AND 1ST FL SHAFT DOOR]
8.6.4.7.1	Clean the elevator pit.
2.27.1.1.2	Put the in car emergency telephone in proper working order.
5.1.21.1	Put the in car alarm bell in working order.
8.6.4.8.2	Remove all materials from machine room (machinery space) not pertaining to the maintenance or operation of the elevator(s).
8.6.4.13.1[k]	Properly maintain door closers, where required. [REPAIR MOTOR ROOM DOOR TO CLOSE AND LOCK ON ITS OWN]
8.11.2.2.2	Perform the annual no load safety test
N/A	CAR SHUT DOWN DUE TO GATE DAMAGED AND OFF TRACK, ALSO DUE TO 2ND FLOOR SHAFT DOOR TRACK PULLED OUT OF WALL FROM BOTTOM UP TO HALF WAY.

Elevator Name: # 3

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: DENNIS PARKS

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SMITHFIELD PACKING  
1911 S. CHURCH ST.  
SMITHFIELD, VA, 23430