N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16253-48-2577
State Number
19902

EQUIPMENT INSPECTED

State Number: **19902**
Capacity: 3500
Landings: 3
Volts: 208

Type of Unit: Passenger
Manuf: OTIS
Installed: 05/07/2001
Complied: 05/15/2001

Floor to Floor: 1 to 3
Speed: 150
Rope Size:
Entrances: 1

OWNER
SEATRAIL CORP0RATION
279 CLUBHOUSE RD
SUNSET BEACH, NC, 28668

OCCUPANT
SEA TRAIL CHAMPIONS BLDG. #34
133 AVIAN DR
SUNSET BEACH, NC, 28668

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
09/09/2016	Routine	Re-issued	48 - Martin	BRUNSWICK	10

VIOLATIONS

2.2.5.1 Put the pit lights in proper working order.

Items must be corrected by: 10/09/2016

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
SEATRAIL CORP0RATION
279 CLUBHOUSE RD
SUNSET BEACH, NC, 28668