



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16253-48-419
State Number
20861

EQUIPMENT INSPECTED

State Number: 20861	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 3500	Manuf: OTIS	Speed: 150
Landings: 3	Installed: 10/16/2002	Rope Size: 0
Volts: 208	Complied: 10/16/2002	Entrances: 1

OWNER

SEA TRAIL CORPORATION
279 CLUBHOUSE ROAD
SUNSET BEACH, NC, 28468

OCCUPANT

SEA TRAIL CHAMPIONS #36
139 AVIAN DRIVE
SUNSET BEACH, NC, 28468

INSPECTION INFORMATION

Inspection Date 09/09/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.26.12 Provide Braille where needed. [2ND AND 3RD FLS]

Items must be corrected by: 10/09/2016

Elevator Name: # 3

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SEA TRAIL CORPORATION
279 CLUBHOUSE ROAD
SUNSET BEACH, NC, 28468