



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**16256-48-2776**  
State Number  
**21563**

EQUIPMENT INSPECTED

State Number: <b>21563</b>	Type of Unit: Passenger	Floor to Floor: 3 to 2
Capacity: 3500	Manuf: OTIS	Speed: 150
Landings: 1	Installed: 05/27/2003	Rope Size:
Volts: 208	Complied: 06/03/2003	Entrances: 0
OWNER	OCCUPANT	
SEA TRAIL CORPORATION	SEA TRAIL CAMPION #37	
279 CLUBHOUSE ROAD	140 AVIAN DR.	
SUNSET BEACH, NC, 28468	SUNSET BEACH, NC, 28468	

INSPECTION INFORMATION

Inspection Date 09/12/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.7.2	Provide the Phase II fire service instructions in the elevator.
2.27.3.1	Put the Phase I fire service feature in proper working order. [FIRE HAT IN CAR]
2.27.1.1.2	Put the in car emergency telephone in proper working order.

Items must be corrected by: 11/12/2016

Elevator Name: # 4

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:  
SEA TRAIL CORPORATION  
279 CLUBHOUSE ROAD  
SUNSET BEACH, NC, 28468