N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16258-37-0171
State Number
30448

EQUIPMENT INSPECTED

State Number: **30448**	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: TKE	Speed: 150
Landings: 3	Installed:	Rope Size:
Volts: 460	Complied:	Entrances: 1

OWNER	OCCUPANT
ELON UNIVERSITY	ELON UNIVERSITY COMMUNICATIONS/PAVILION
CAMPUS BPX 84823	129 N WILLIAMSON AVENUE
ELON, NC, 27244	BURLINGTON, NC, 27244

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
09/14/2016	New	Not Issued	37 - Hopper	ALAMANCE

1

VIOLATIONS

2.27 PUT THE SMOKEHEADS IN PROPER WORKING ORDER

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: BOB

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ELON UNIVERSITY
CAMPUS BPX 84823
ELON, NC, 27244