



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16259-65-3236
State Number
23277

EQUIPMENT INSPECTED

State Number: 23277	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 80
Landings: 2	Installed: 07/28/2005	Rope Size: 0
Volts: 208	Complied: 02/16/2006	Entrances: 1

OWNER
ELK RIVER COUNTRY CLUB
1000 CLUBHOUSE DRIVE
BANNER ELK, NC, 28604

OCCUPANT
ELK RIVER CLUBHOUSE
235 CLUB HOUSE DRIVE
BANNER ELK, NC, 28604

INSPECTION INFORMATION

Inspection Date 09/15/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 65 - Kelley	County AVERY
-------------------------------	----------------------------	---------------------------------	--------------------------	-----------------

6

VIOLATIONS

8.6.1.6.5 Provide the required fire extinguisher in the machine room. (Expired)

Items must be corrected by: 11/15/2016

Elevator Name: # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Elk River Clubhouse 828-896-9773

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELK RIVER COUNTRY CLUB
1000 CLUBHOUSE DRIVE
BANNER ELK, NC, 28604