



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16265-48-0313
State Number
15103

EQUIPMENT INSPECTED

State Number: 15103	Type of Unit: Passenger	Floor to Floor: G to 2
Capacity: 2100	Manuf: OTIS	Speed: 125
Landings: 3	Installed: 10/12/1993	Rope Size:
Volts: 208	Complied: 10/12/1993	Entrances: 1
OWNER	OCCUPANT	
OCEAN GREENS CONDO ASSOC.	OCEAN GREENS BLDG #1	
OCEAN GREENS LANE	51-54 FOX FIRE LN.	
CASWELL BEACH, NC, 28465	CASWELL BEACH, NC, 28465	

INSPECTION INFORMATION

Inspection Date 09/21/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.8.1	Clean the elevator machine room.
8.6.4.7.1	Clean the elevator pit.

Items must be corrected by: 11/21/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

OCEAN GREENS CONDO ASSOC.
OCEAN GREENS LANE
CASWELL BEACH, NC, 28465