



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16265-48-3752
State Number
21075

EQUIPMENT INSPECTED

State Number: 21075	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: SCHINDLER	Speed: 100
Landings: 3	Installed: 06/20/2002	Rope Size: .
Volts: 208	Complied: 06/24/2002	Entrances: 1

OWNER
OCEAN GREENS CONDO ASSOC
77 FOXFIRE DR #6
CASWELL BEACH, NC, 28465

OCCUPANT
OCEAN GREEN CONDO #6
75-78 FOX FIRE TRACE
CASWELL BEACH, NC, 28465

INSPECTION INFORMATION

Inspection Date 09/21/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

Elevator Name: #6

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

OCEAN GREENS CONDO ASSOC
77 FOXFIRE DR #6
CASWELL BEACH, NC, 28465