



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**16266-37-015**  
State Number  
**H2762**

EQUIPMENT INSPECTED

State Number: <b>H2762</b>	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: SAVARIA	Speed: 8
Landings: 2	Installed:	Rope Size:
Volts: 120	Complied:	Entrances: 2
OWNER	OCCUPANT	
LIDL US LLC	MGP DISTRIBUTION	
3500 S CLARK STREET	2180 KIMREY ROAD	
ARLINGTON, VA, 22202	MEBANE, NC, 27032	

INSPECTION INFORMATION

Inspection Date 09/21/2016	Type Inspection New	Certificate Status Not Issued	Inspector 37 - Hopper	County ALAMANCE
-------------------------------	------------------------	----------------------------------	--------------------------	--------------------

1

VIOLATIONS

211.1	PUT THE EMERGENCY LIGHT IN WORKING ORDER
211.1	PUT THE PHONE IN WORKING ORDER

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Richard Shaffner 704-905-0870

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LIDL US LLC  
3500 S CLARK STREET  
ARLINGTON, VA, 22202