



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16280-38-5262
State Number
30671

EQUIPMENT INSPECTED

State Number: 30671	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: VERT EXP	Speed: 150
Landings: 3	Installed: 10/06/2016	Rope Size:
Volts: 480	Complied: 10/06/2016	Entrances: 1
OWNER	OCCUPANT	
ASHEVILLE ART MUSEUM	DIANA WORTHAM THEATRE	
2 S PACK SQUARE	2 S PACK SQUARE	
ASHEVILLE, NC, 28801	ASHEVILLE, NC, 28801	

INSPECTION INFORMATION

Inspection Date 10/06/2016	Type Inspection New	Certificate Status Issued	Inspector 38 - Raborn	County BUNCOMBE	11 A
-------------------------------	------------------------	------------------------------	--------------------------	--------------------	------

VIOLATIONS

NOTE UNIT IN COMPLIANCE WITH A17.1
NOTE WORK PRESS= 320 RELIEF PRESS= 445 RUNBY TOP= 7in RUNBY BOTTOM= 5 5/8in

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Randy Barlett 828.274.3633

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHEVILLE ART MUSEUM
2 S PACK SQUARE
ASHEVILLE, NC, 28801