



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16281-65-0234
State Number
29530

EQUIPMENT INSPECTED

State Number: 29530	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 5000	Manuf: SCHINDLER	Speed: 150
Landings: 2	Installed: 09/15/2014	Rope Size:
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
LEES MCRAE COLLEGE	LEES MCRAE SCHOOL OF NURSING	
191 MARTIN STREET WEST	191 MARTIN STREET WEST	
BANNER ELK, NC, 28604	BANNER ELK, NC, 28604	

INSPECTION INFORMATION

Inspection Date 10/07/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 65 - Kelley	County AVERY
-------------------------------	----------------------------	---------------------------------	--------------------------	-----------------

6

VIOLATIONS

8.6.4.8.2 Articles or materials not necessary for the maintenance or operation of the elevator shall not be stored in machine rooms and machinery spaces.
8.11.3.2.1 Perform the annual relief valve test

Items must be corrected by: 12/07/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Paul Braese 828-645-0229

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LEES MCRAE COLLEGE
191 MARTIN STREET WEST
BANNER ELK, NC, 28604