



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16281-70-4161
State Number
17537

EQUIPMENT INSPECTED

State Number: 17537	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 3	Installed: 06/22/1998	Rope Size:
Volts: 208	Complied: 05/27/2003	Entrances: 1
OWNER	OCCUPANT	
CASPN HOMES LLC	CASPN ELDERLY HOUSING	
338 W.WAINMAN AVE/ PO BOX 609	945 SOUTH CHURCH ST	
ASHEBORO, NC, 27204-0609	ASHEBORO, NC, 27204	

INSPECTION INFORMATION

Inspection Date 10/07/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 70 - Darnley	County RANDOLPH
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

76

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.(Call is placed and answered but two way communication does not work and phone keeps redialing)

Elevator Name: 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainance with current codes.

Violations pointed out to: No One on site left report in box of apt 111

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CASPN HOMES LLC
338 W.WAINMAN AVE/ PO BOX 609
ASHEBORO, NC, 27204-0609