



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**16286-70-2220**  
State Number  
**613**

EQUIPMENT INSPECTED

State Number: <b>613</b>	Type of Unit: Freight	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: MONARCH	Speed: 50
Landings: 2	Installed: 12/21/1945	Rope Size: 1/2
Volts: 220	Complied: 06/25/2004	Entrances: 1
OWNER	OCCUPANT	
WILLIAM IVEY	SOUTHERN ANTIQUES & POTTERY/ CLOCK SHOP	
118 S CHURCH ST	118 S CHURCH ST	
ASHEBORO, NC, 27203	ASHEBORO, NC, 27203	

INSPECTION INFORMATION

Inspection Date 10/12/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 70 - Darnley	County RANDOLPH
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

76

VIOLATIONS

- 8.6 Perform required safety Testing
- 8.6 Adjust car gate to stay closed during operation of elevator
- 8.6 Make Emergency phone operative

Items must be corrected by: 11/11/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Dennis Robbins

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WILLIAM IVEY  
118 S CHURCH ST  
ASHEBORO, NC, 27203