



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16293-48-5830
State Number
23453

EQUIPMENT INSPECTED

State Number: 23453	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 3000	Manuf: OTIS	Speed: 150
Landings: 3	Installed: 12/05/2005	Rope Size: 0
Volts: 208	Complied: 12/05/2005	Entrances: 1
OWNER	OCCUPANT	
COMMUNITY ASSOCIATION MANAGEMENT	COLONY II BLDG 8	
PO BOX 8126	908 RESORT CIRCLE	
OCEAN ISLE BEACH, NC, 28469	SUNSET BEACH, NC, 28467	

INSPECTION INFORMATION

Inspection Date 10/19/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.3.1	Put the Phase I fire service feature in proper working order. [NO FIRE RECALL LIGHT AT KEY SW]
2.26.12	Provide Braille where needed. [3RD FL]
8.6.8.9	Signs. Caution signs shall be provided. Damaged or missing signs shall be replaced. [3RD FL]

Items must be corrected by: 12/19/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

COMMUNITY ASSOCIATION MANAGEMENT
PO BOX 8126
OCEAN ISLE BEACH, NC, 28469