



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16294-48-4821
State Number
23405

EQUIPMENT INSPECTED

State Number: 23405	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 3500	Manuf: OTIS	Speed: 150
Landings: 3	Installed: 10/12/2005	Rope Size:
Volts: 208	Complied: 10/12/2005	Entrances: 2

OWNER

THE RED APPLE GROUP, LLC
712 VILLAGE ROAD
SHALLOTTE, NC, 28470

OCCUPANT

RED APPLE PROFESSIONAL PARK
712 VILLAGE ROAD, SW
SHALLOTTE, NC, 28470

INSPECTION INFORMATION

Inspection Date 10/20/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.3.1 Put the Phase I fire service feature in proper working order. [NO LIGHT AT KEY SW.] [SAME AS LAST YR.]

Items must be corrected by: 12/20/2016

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

THE RED APPLE GROUP, LLC
712 VILLAGE ROAD
SHALLOTTE, NC, 28470