



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**16295-70-0795**  
State Number  
**6830**

EQUIPMENT INSPECTED

State Number: <b>6830</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 1500	Manuf: STHERN	Speed: 100
Landings: 2	Installed: 10/21/1970	Rope Size:
Volts: 220	Complied: 10/21/1970	Entrances: 1
OWNER	OCCUPANT	
WAYNE PARKER	ALUMIWORKS	
900 N MAIN STREET	900 N MAIN STREET	
RANDLEMAN, NC, 27317	RANDLEMAN, NC, 27317	

INSPECTION INFORMATION

Inspection Date 10/21/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 70 - Darnley	County RANDOLPH
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

76

VIOLATIONS

- 8.6.4.7.4 Water and oil shall not be allowed to accumulate on pit floors.
- 2.14.7.1 Put the car lights in proper working order.
- 8.6.4.15 Emergency operation of signaling devices, lighting, communication, and ventilation, shall be maintained. (alarm bell)
- 8.11.3.2.1 Provide the annual relief valve and system pressure test.

Items must be corrected by: 11/20/2016

Elevator Name: PASSENGER ELEV

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Wayne Parker

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WAYNE PARKER  
900 N MAIN STREET  
RANDLEMAN, NC, 27317