



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**16312-48-239**  
State Number  
**23253**

#### EQUIPMENT INSPECTED

State Number: <b>23253</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 4500	Manuf: OTIS	Speed: 150
Landings: 3	Installed: 02/07/2006	Rope Size: .
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
SAIEED CONSTRUCTION	WATERFORD MEDICAL BLDG.	
1135 MILITARY CUTOFF	509 OLD WATERFORD WAY	
WILMINGTON, NC, 28405	LELAND, NC, 28451	

#### INSPECTION INFORMATION

Inspection Date 11/07/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

#### VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 01/07/2017

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: H. BURGESS

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SAIEED CONSTRUCTION  
1135 MILITARY CUTOFF  
WILMINGTON, NC, 28405