



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16312-70-0195
State Number
16142

EQUIPMENT INSPECTED

State Number: **16142**

Capacity: 8000

Landings: 4

Volts: 480

Type of Unit: Passenger

Manuf: THYSSEN KRUPP

Installed: 03/28/1996

Complied: 04/10/1996

Floor to Floor: 1 to 4

Speed: 100

Rope Size: 5/8

Entrances: 1

OWNER

STARPET INC

801 PINEVIEW RD

ASHEBORO, NC, 27203

OCCUPANT

STARPET INC

801 PINEVIEW RD

ASHEBORO, NC, 27203

INSPECTION INFORMATION

Inspection Date
11/07/2016

Type Inspection
Routine

Certificate Status
Re-issued

Inspector
70 - Darnley

County
RANDOLPH

76

VIOLATIONS

8.1.1[c] Keys shall be kept on the premises in a location readily accessible to the personnel in the assigned group, but not where they are accessible to the general public.

Items must be corrected by: 12/07/2016

Elevator Name: CP BLDG

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: John Cannon

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

STARPET INC
801 PINEVIEW RD
ASHEBORO, NC, 27203