N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16322-48-4486
State Number
20788

EQUIPMENT INSPECTED

State Number: **20788**
Capacity: 2100
Landings: 2
Volts: 208

Type of Unit: Passenger
Manuf: SCHINDLER
Installed: 04/22/2002
Complied: 04/24/2002

Floor to Floor: 1 to 2
Speed: 100
Rope Size:
Entrances: 2

OWNER
ELIZABETHTOWN BAPTIST CHURCH
1800 W BROAD ST
ELIZABETHTOWN, NC, 28337

OCCUPANT
ELIZABETHTOWN BAPTIST CHURCH
1800 W BROAD ST
ELIZABETHTOWN, NC, 28337

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
11/17/2016	Routine	Re-issued	48 - Martin	BLADEN

9

VIOLATIONS

3.24.1 Elevator pumping unit. [EMPTY OIL FROM PAN IN PIT]

Items must be corrected by: 01/17/2017

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: LINDA

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ELIZABETHTOWN BAPTIST CHURCH
1800 W BROAD ST
ELIZABETHTOWN, NC, 28337