N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16322-70-0736
State Number
25634

EQUIPMENT INSPECTED

State Number: **25634**
Capacity: 20000
Landings: 2
Volts: 480

Type of Unit: Freight
Manuf: OTIS
Installed: 12/22/2008
Complied:

Floor to Floor: 1 to 2
Speed: 50
Rope Size:
Entrances: 1

OWNER
MALT O MEAL
2525 BANK STREET
ASHBORO, NC, 27203

OCCUPANT
MALT O MEAL
2525 BANK STREET
ASHBORO, NC, 27203

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
11/17/2016	Routine	Re-issued	70 - Darnley	RANDOLPH

76

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 12/17/2016

Elevator Name: RTE BLDG LINE 1 & 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Al Spencer

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
MALT O MEAL
2525 BANK STREET
ASHBORO, NC, 27203