N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16334-37-1795
State Number
9310

EQUIPMENT INSPECTED

State Number: **9310**
Capacity: 4000
Landings: 3
Volts: 208

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 07/30/1979
Complied: 07/13/2001

Floor to Floor: 1 to 3
Speed: 100
Rope Size:
Entrances: 1

OWNER
BURLINGTON HOUSING AUTHORITY
133 N IRELAND
BURLINGTON, NC, 27217

OCCUPANT
BURLINGTON HOMES
507 EVERETT ST
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
11/29/2016	Routine	Re-issued	37 - Hopper	ALAMANCE

1

VIOLATIONS

8.6 PROVIDE PROPER TEST TAG ON CONTROLLER
8.6 TAKE STEPS TO ELIMINATE CAR SCRAPPING
8.6 REMOVE OIL CAN FROM CARTOP
8.6 UPDATE THE FIRE EXTINGUISHER

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: KIRKWEBSTER 336-516-3545 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to: BURLINGTON HOUSING AUTHORITY
133 N IRELAND
BURLINGTON, NC, 27217