



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16347-48-3132
State Number
25221

EQUIPMENT INSPECTED

State Number: 25221	Type of Unit: Passenger	Floor to Floor: 1 to 5
Capacity: 3500	Manuf: OTIS	Speed: 150
Landings: 5	Installed: 02/22/2008	Rope Size:
Volts: 208	Complied: 02/22/2008	Entrances: 1
OWNER		OCCUPANT
REGENCY CONDO HOA CAMS INC.		REGENCY CONDOS BLDG 3
1630 MILITARY CUTOFF RD. STE 108		915 SHORELINE DR. W.
WILMINGTON, NC, 28403		SUNSET BEACH, NC, 28467

INSPECTION INFORMATION

Inspection Date 12/12/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 02/12/2017

Elevator Name: # 3

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: A. Compton

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

REGENCY CONDO HOA CAMS INC.
1630 MILITARY CUTOFF RD. STE 108
WILMINGTON, NC, 28403