N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16348-65-5554
State Number
29485

EQUIPMENT INSPECTED

State Number: **29485**	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: VERT EXP	Speed: 95
Landings: 2	Installed: 08/13/2014	Rope Size:
Volts: 460	Complied:	Entrances: 1

OWNER	OCCUPANT
ASHEVILLE CHRISTIAN ACADEMY	ASHEVILLE CHRISTIAN ACADEMY STUDENT CTR
74 RIVERWOOD	74 RIVERWOOD
SWANNANOA, NC, 28778	SWANNANOA, NC, 28778

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
12/13/2016	Routine	Re-issued	65 - Kelley	BUNCOMBE	11 B

VIOLATIONS

8.6.4.7.1 Clean the elevator hoistway. (Remove wood in overhead)

Items must be corrected by: 01/12/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Mark Brant 828-545-8234 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ASHEVILLE CHRISTIAN ACADEMY
74 RIVERWOOD
SWANNANOA, NC, 28778