



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**16350-73-4538**  
State Number  
**17003**

EQUIPMENT INSPECTED

State Number: <b>17003</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 135
Landings: 3	Installed: 09/24/1997	Rope Size:
Volts: 208	Complied: 09/24/1997	Entrances: 1
OWNER	OCCUPANT	
CHATEAU PROP., INC	COUNTRY SUITES BY CARLSON	
10000 TALLENT LANE	3211 WILSON DR	
HUNTERSVILLE, NC, 28078	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 12/15/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: front desk

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CHATEAU PROP., INC  
10000 TALLENT LANE  
HUNTERSVILLE, NC, 28078