N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16363-73-1842
State Number
18675

EQUIPMENT INSPECTED

State Number: **18675**
Capacity: 2100
Landings: 2
Volts: 208

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 10/28/1999
Complied: 11/17/1999

Floor to Floor: 1 to 2
Speed: 95
Rope Size:
Entrances: 1

OWNER
FIRST PRESBYTERIAN CHURCH
508 W DAVIS ST
BURLINGTON, NC, 27215

OCCUPANT
FIRST PRESBYTERIAN CHURCH
508 W DAVIS ST
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
12/28/2016	Routine	Re-issued	73 - James	ALAMANCE

1

VIOLATIONS

8.6 Elevator machiune room not to be used for storage

Items must be corrected by: 02/28/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Secretary

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
FIRST PRESBYTERIAN CHURCH
508 W DAVIS ST
BURLINGTON, NC, 27215