N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16363-73-4663
State Number
26563

EQUIPMENT INSPECTED

State Number: **26563**
Capacity: 2100
Landings: 2
Volts: 200

Type of Unit: Passenger
Manuf: TKE
Installed: 03/09/2009
Complied:

Floor to Floor: 1 to 2
Speed: 80
Rope Size:
Entrances: 2

OWNER
FIRST PRESBYTERIAN CHURCH
508 W DAVIS STREET
BURLINGTON, NC, 27215

OCCUPANT
FIRST PRESBYTERIAN CHURCH
508 W DAVIS STREET
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
12/28/2016	Routine	Re-issued	73 - James	ALAMANCE

1

VIOLATIONS

8.6 Elevator equipment room not to be used for storage

Items must be corrected by: 02/28/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Secretary

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
FIRST PRESBYTERIAN CHURCH
508 W DAVIS STREET
BURLINGTON, NC, 27215