N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16363-73-4729
State Number
6040

EQUIPMENT INSPECTED

State Number: **6040**
Capacity: 2500
Landings: 4
Volts: 480

Type of Unit: Passenger
Manuf: SOUTHERN
Installed: 09/06/1968
Complied: 06/12/1987

Floor to Floor: G to 3
Speed: 100
Rope Size:
Entrances: 1

OWNER
FIRST BAPTIST CHURCH
PO BOX 2686
BURLINGTON, NC, 27216-2686

OCCUPANT
FIRST BAPTIST CHURCH
400 S BROAD ST
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
12/28/2016	Routine	Re-issued	73 - James	ALAMANCE

1

VIOLATIONS

8.6.4.13.1[l] Properly maintain door restrictors, where required. (car door)

Items must be corrected by: 02/28/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Danny

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
FIRST BAPTIST CHURCH
PO BOX 2686
BURLINGTON, NC, 27216-2686