



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**16364-73-4293**  
State Number  
**29537**

EQUIPMENT INSPECTED

State Number: <b>29537</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 1400	Manuf: CUSTOM ELEV INC	Speed: 30
Landings: 3	Installed: 08/04/2014	Rope Size:
Volts: 480	Complied: 08/04/2014	Entrances: 2

OWNER

FIRST BAPTIST CHURCH  
508 APPLE STREET  
BURLINGTON, NC, 27215

OCCUPANT

FIRST BAPTIST CHURCH  
508 APPLE STREET  
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date 12/29/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

2.27.1.1.2	Put the in car emergency telephone in proper working order.
8.6	Change battery in smoke alarm in machine room
8.6	Maintain fire extinguisher

Items must be corrected by: 02/28/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Frankie Enoch

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

FIRST BAPTIST CHURCH  
508 APPLE STREET  
BURLINGTON, NC, 27215