



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17004-73-1576**  
State Number  
**27992**

EQUIPMENT INSPECTED

State Number: <b>27992</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 3500	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 12/16/2011	Rope Size:
Volts: 480	Complied: 12/16/2011	Entrances: 1
OWNER	OCCUPANT	
LANDMARK GROUP	MEBANE MILLS LOFTS	
401 N HERITAGE STREET	301 W WASHINGTON STREET	
WINSTON SALEM, NC, 27101	MEBANE, NC, 27302	

INSPECTION INFORMATION

Inspection Date 01/04/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6.4.7.4	Water and oil shall not be allowed to accumulate on pit floors.
2.27.1.1.2	Put the in car emergency telephone in proper working order.

Items must be corrected by: 03/04/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Front office

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LANDMARK GROUP  
401 N HERITAGE STREET  
WINSTON SALEM, NC, 27101