



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17006-73-0143**  
State Number  
**24497**

#### EQUIPMENT INSPECTED

State Number: <b>24497</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: OTIS	Speed: 125
Landings: 3	Installed: 01/12/2007	Rope Size:
Volts: 208	Complied: 01/12/2007	Entrances: 1
OWNER	OCCUPANT	
ELON UNIVERSITY	OAKS BUILDING (F)	
803 HAGGARD AVENUE	416 N WILLIAMSON AVE	
ELON, NC, 27244	ELON, NC, 27244	

#### INSPECTION INFORMATION

Inspection Date 01/06/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

#### VIOLATIONS

8.6 Clean elevator pit

Items must be corrected by: 03/06/2017

Elevator Name: BUILDING (F)

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jeremy Lloyd

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSITY  
803 HAGGARD AVENUE  
ELON, NC, 27244