



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17011-73-1313
State Number
24931

EQUIPMENT INSPECTED

State Number: 24931	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 80
Landings: 3	Installed: 07/17/2007	Rope Size: 0
Volts: 208	Complied: 07/17/2007	Entrances: 1
OWNER	OCCUPANT	
R K HOSPITALITY GROUP	COLONNADES- MOFFITT HALL (B)	
100 WOODLAKE PARKWAY	336 DALTON MCMICHAEL DR	
KINGS MOUNTAIN, NC, 28086	ELON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 01/11/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6.1.4.1[a]	Properly document maintenance records
2.14.7.1	Put the car lights in proper working order.
8.6.4.13.1[l]	Properly maintain door restrictors, where required.
8.11.3.2.1	Provide the annual relief valve and system pressure test.
8.6	Clean the elevator pit

Items must be corrected by: 03/11/2017

Elevator Name: MOFFITT HALL (B)

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Rick

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

R K HOSPITALITY GROUP
100 WOODLAKE PARKWAY
KINGS MOUNTAIN, NC, 28086