



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17011-73-1874**  
State Number  
**14909**

EQUIPMENT INSPECTED

State Number: <b>14909</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 02/01/1994	Rope Size:
Volts: 480	Complied: 02/01/1994	Entrances: 1
OWNER	OCCUPANT	
ELON UNIVERSTIY	KOURY CENTER (MAIN CONCOURSE)	
803 HAGGARD AVENUE	104 E HAGGARD AVE	
ELON, NC, 27244	ELON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 01/11/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

5.1.21.1	Put the in car alarm bell in working order.
8.6	Tighten loose pickup roller on bottom door
8.6	Put car door restrictor in working order
8.6	Perform annual pressure test

Items must be corrected by: 03/11/2017

Elevator Name: Koury cebter main concors

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Rick

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSTIY  
803 HAGGARD AVENUE  
ELON, NC, 27244