



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17011-73-3640
State Number
27613

EQUIPMENT INSPECTED

State Number: 27613	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: TKE	Speed: 100
Landings: 3	Installed: 08/05/2011	Rope Size:
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
ELON UNIVERSITY	COLONNADES - HARPER HALL (E)	
100 CAMPUS DRIVE CB 2060	525 E PHOENIX DRIVE	
ELON, NC, 27244	ELON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 01/11/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.(Location not on record)

Items must be corrected by: 03/11/2017

Elevator Name: HARPER HALL (E)

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Rick

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSITY
100 CAMPUS DRIVE CB 2060
ELON, NC, 27244